

Underground Service Entrance Cable



Construction: The stranded aluminum or aluminum alloy conductor is insulated with XLPE.



Application: This product is suitable for use in transmission and distribution system at rated voltage 600V or less.



Operating Temperature: Max permissible continuous operating temperature of conductor shall not exceed 90°C.



Standard : UL 874, ASTM B231, ASTM B399 or other standards required by customers.



Packing: Coil, steel/wooden reel, wooden reel or steel reel.



Underground Service Entrance Cable

Code Word	Size	Insulation Diameter	Code Word	Size	Insulation Diameter
	AWG or MCM	inch		AWG or MCM	inch
---	8	0.27	Beloit	4/0	0.70
Princeton	6	0.31	Hofstra	250	0.78
Mercer	4	0.36	Gonzaga	300	0.83
Clemson	2	0.42	Rutgers	350	0.88
Kenyon	1	0.50	Emory	400	0.93
Harvard	1/0	0.54	Duke	500	1.01
Yale	2/0	0.59	Furman	600	1.12
Tufts	3/0	0.64	Sawanee	750	1.23